

---

**Subject:** Lead and Copper Results

**Date:** October 17, 2024

**PWSID:** 1170009

**System Name:** Red Rock Rural Water System

---

**Results summary:**

- ❖ **No exceedance in lead or copper action levels.**
- ❖ 90<sup>th</sup> percentile lead: 2 µg/L.
- ❖ 90<sup>th</sup> percentile copper: 493 µg/L.
- ❖ Current monitoring period for lead and copper: 3-years.
- ❖ Next round of monitoring: **June - September 2027**
- ❖ Number of samples to be collected in next monitoring period: **20** samples.

**Recommended actions:**

**Red Rock Rural Water System** has done well in maintaining action levels through its sixth triennial monitoring round. The system had submitted a site plan detailing the sites they were using as required by MDH. The system should contact MDH with any changes or updates related to lead and copper sampling or treatment.

**Additional Information:**

It is the system's responsibility to get samples collected from the best sites available in the distribution with respect to the current sample site tier criteria. As you continue to confirm more information about the sites available in the distribution, you should ensure to update your sample site plan accordingly to comply with rule requirements. You can find resources on sample site plan development on the MDH "Lead and Copper Site Plan Updates web page here: [Lead and Copper Site Plan Updates - MN Dept. of Health \(state.mn.us\)](https://www.health.state.mn.us/leadandcopper/siteplanupdates/)

MDH encourages all public water supplies to actively provide educational material about reducing exposure to lead and/or copper in drinking water. For more information that you can provide residents please see our "Lead in Drinking Water" web page on the MDH website:

<https://www.health.state.mn.us/communities/environment/water/contaminants/lead.html>

Or scan this QR code from your mobile device:



**Contact Information:**

Please contact your District Engineer or DWP Compliance Officer, Jackie Becker at 651-478-0805 with any questions relating to the Lead and Copper Rule and/or corrosion control treatment and treatment optimization, and pre-notify MDH of any treatment modifications or changes by emailing [Jackie.r.becker@state.mn.us](mailto:Jackie.r.becker@state.mn.us).